



**NOTES:**

1. OTHER UTILITES TO KEEP A 12" MINIMUM SEPARATION FROM PUD 3 CABLE.
2. SELECT BACKFILL TO BE FURNISHED BY CONTRACTOR.

SCALE	NONE	<b>ENGINEERING STANDARD</b> <b>CONDUCTOR UNDERGROUND INSTALLATION OF PUD3 CABLE</b> <b>AND OTHER UTILITIES</b>  <small>DEPARTMENT of ENGINEERING</small> <b>PUBLIC UTILITY DISTRICT NO.3 of MASON COUNTY</b> <small>SHELTON, WASHINGTON</small>	DSGN. BY	D.HORA	
DATE	JAN 1982		DR. BY	D. HORA	
APPROVED BY			CH. BY		
RLF			SHEET	1	of
CHB		DRAWING NUMBER	507.13		REV NO
DR					4